



# Calculations Used in the Daily Operations of a Wastewater Treatment Facility



[www.baxterwoodman.com](http://www.baxterwoodman.com)



The calculations provided in this booklet are tools, much like the equipment utilized, that will enable the operator to manage and run a wastewater treatment facility as efficiently and smoothly as possible.

Operating a treatment facility can be challenging, yet very rewarding. These plants are designed using parameters that take into account various hydraulic and organic loadings, and with equipment that will allow for efficient operation. However, running the equipment alone is not enough to ensure a smooth operation. The operator must use the calculations provided to operate the plant in an effective manner. While the operator can choose which calculations to use, it is imperative that the facility is run following operational guidelines.

We hope you find this guide helpful.  
If you have any questions or need further assistance,  
please call Baxter & Woodman at 815-459-1260.

## Contents

<b>Areas &amp; Volumes</b> .....	2
<b>Raw Influent Calculations</b>	
Plant Influent Loadings .....	2
<b>Clarifier Capacity Calculations</b>	
Surface Loading Rate - Rectangular Clarifier .....	3
Surface Loading Rate - Circular Clarifier .....	3
Detention Time.....	4
Weir Overflow Rate .....	4
<b>Activated Sludge Calculations</b>	
Sludge Age .....	5
Solids Retention Time (SRT).....	6
F/M Ratio.....	7
MLSS Concentration in Pounds.....	7
Solids to be Wasted .....	7
Waste Sludge Pumping Rate.....	8
Typical WWTP Operational Parameters.....	8
Metal Salt Addition for Phosphorus Removal.....	9
<b>Baxter &amp; Woodman Services</b> .....	10

---

## Calculations Used in the Daily Operation of a Wastewater Treatment Facility

Several basic equations are used in calculations to determine things such as Weir Overflow Rate, Detention Time, SRT, etc. The formulas for area and volume appear below, along with examples.

### AREA

Area	Formula	Example
Rectangle	(Length) x (Width)	(35' L) x (12' W) = 420 sq. ft.
Circle	(0.785) x (Dia. sq.)	(0.785) x (55') x (55') = 2,375 sq. ft.

### VOLUME

Volume	Formula	Example
Rectangle	L x W x H	80'L x 25'W x 10"H = 20,000 cu. ft.
Cylinder	(0.785) x (Dia. sq.) x (H)	(0.785) x (55') x (55') x (25') = 59,366 cu. ft.

## Raw Influent Calculations

### Plant Influent Loadings

Determines the influent loadings of pounds (BOD, TSS, etc.) to a wastewater treatment facility.

$$\text{Plant Influent Loadings:} \\ \text{mg/l} \times \text{mgd} \times 8.34 = \text{lbs./day}$$

*Example (using TSS):*

Plant Conditions:

TSS Influent = 135 mg/l

Influent flow = 1.5 mgd

To determine pounds into the plant, use the following calculation:

$$\text{mg/l} \times \text{mgd} \times 8.34 = \text{lbs./day}$$

*Example:* 135 mg/l x 1.5 mgd x 8.34 = 1,688.85 lbs.

*This reflects the pounds of TSS into the plant on that particular day.*

## Clarifier Capacity Calculations

### Surface Loading Rate - RECTANGULAR Clarifier

Gallons of wastewater applied to each square foot of the clarifier area. This affects the settleable solids and BOD removal efficiency in the sedimentation process.

**Surface Loading Rate (RECTANGULAR CLARIFIER):**  
$$\frac{\text{gpd}}{\text{sq. ft. of clarifier}}$$

*Example:*  
Clarifier:  
Length = 75 feet  
Width = 12 feet  
Influent flow = 1.2 mgd (1,200,000 gpd)

The square footage of the clarifier is L x W:  
75 x 12 = 900 sq. ft.

To determine the Surface Loading Rate of a **rectangular** clarifier, use the following calculation:

$$\frac{\text{gpd}}{\text{sq. ft. of clarifier}}$$

*Example:*  $\frac{1,200,000 \text{ gpd}}{900 \text{ sq. ft.}} = 1,333 \text{ gpd/sq. ft.}$

## Clarifier Capacity Calculations

### Surface Loading Rate - CIRCULAR Clarifier

Gallons of wastewater applied to each square foot of the clarifier area. This affects the settleable solids and BOD removal efficiency in the sedimentation process.

**Surface Loading Rate (CIRCULAR CLARIFIER):**  
$$\frac{\text{gpd}}{\text{sq. ft. of clarifier}}$$

*Example:*  
Clarifier:  
Diameter = 60 feet  
Influent flow = 2,200,000 gpd

The square footage of the clarifier is .785 x Dia. sq.  
.785 x 60' x 60' = 2,826 sq. ft.

To determine the Surface Loading Rate of a **circular** clarifier, use the following calculation:

$$\frac{\text{gpd}}{\text{sq. ft. of clarifier}}$$

*Example:*  $\frac{2,200,000 \text{ gpd}}{2,826 \text{ sq. ft.}} = 778.48 \text{ gpd/sq. ft.}$

---

## Clarifier Capacity Calculations

### Detention Time

Period of time that a particle remains in a tank.

$$\text{Detention Time:} \\ \frac{\text{tank volume x 24 hours}}{\text{Influent flow}}$$

*Example (rectangular clarifier):*

Clarifier:

Length = 75 feet

Width = 30 feet

Depth = 10 feet

Influent flow = 2,850,000 gpd

The volume of the clarifier is L x W x H x 7.48

$$70' \times 25' \times 10' \times 7.48 = 130,900 \text{ gals.}$$

To determine the Detention Time of a **rectangular** clarifier, use the following calculation:

$$\frac{\text{tank volume x 24 hours}}{\text{Influent flow}}$$

*Example:* 
$$\frac{130,900 \text{ gals} \times 24}{2,850,000} = 1.10 \text{ hours}$$

## Clarifier Capacity Calculations

### Weir Overflow Rate

Volume of water flowing over foot length of weir per day.

$$\text{Weir Overflow Rate:} \\ \frac{\text{gpd flow}}{\text{Total feet of weir}}$$

*Example:*

Plant Conditions:

Weir length = 100 feet

Flow rate = 1,500,000 gpd

To determine the Weir Overflow Rate, use the following calculation:

$$\frac{\text{gpd flow}}{\text{Total feet of weir}}$$

*Example:* 
$$\frac{1,500,000 \text{ gpd}}{100 \text{ feet of weir}} = 15,000 \text{ gpd/ft.}$$

# Activated Sludge Calculations

## Sludge Age

Average time a particle of suspended solids remains in the activated sludge system. Sludge age is used to maintain the proper amount of activated sludge in the aeration system.

To determine sludge age, you must calculate both the daily amount of suspended solids and the total amount of solids in the aerator.

$$\text{Sludge Age:} \\ \frac{\text{Total lbs. of MLSS in aerator}}{\text{Daily lbs. of MLSS in aerator}}$$

## Sludge Age - Plants with Primary Clarifier

*Example:*

Suspended solids of primary effluent = 110 mg/l  
Influent flow = 2.5 mgd  
Aeration tank volume = .5 mg  
MLSS concentration = 2,200 mg/l

The plant influent loading = **mg/l x mgd x 8.34**

*Example:*

$110 \times 2.5 \times 8.34 = 2,293.5$  lbs. **daily** of SS (lbs of MLSS in aerator)  
 $2,200 \times .5 \times 8.34 = 9,174$  lbs. **total** of MLSS in aerator

With these calculations, you can determine Sludge Age:

$$\frac{\text{Total lbs. of MLSS in aerator}}{\text{Daily lbs. of MLSS in aerator}} = \text{Days Sludge Age}$$

*Example:*

$\frac{9,174 \text{ lbs. total of MLSS in aerator}}{2,293.5 \text{ lbs. daily of MLSS in aerator}} = 4$  Days Sludge Age

## Sludge Age - Plants without Primary Clarifier

*Example:*

Influent suspended solids = 250 mg/l  
Influent flow = 2.5 mgd  
Aeration tank volume = .5 mg  
MLSS concentration = 2,200 mg/l

The plant influent loading = **mg/l x mgd x 8.34**

*Example:*

$250 \times 2.5 \times 8.34 = 5,213$  lbs. **daily** of SS (lbs of MLSS in aerator)  
 $2,200 \times .5 \times 8.34 = 9,174$  lbs. **total** of MLSS in aerator

With these calculations, you can determine Sludge Age:

$$\frac{\text{Total lbs. of MLSS in aerator}}{\text{Daily lbs. of MLSS in aerator}} = \text{Days Sludge Age}$$

*Example:*

$\frac{9,174 \text{ lbs. total of MLSS in aerator}}{5,213 \text{ lbs. daily of MLSS in aerator}} = 1.76$  Days Sludge Age

# Activated Sludge Calculations

## Solids Retention Time (SRT)

Average time a given unit of cell mass stays in the activated sludge system. SRT is based on solids leaving the Activated Sludge process, and includes solids in the clarifiers. Also called MCRT (Mean Cell Residence Time).

$$\text{Solids Retention Time (SRT):}$$
$$\text{SRT days} = \frac{\text{lbs./day of SS in system}}{\text{lbs./day of SS leaving system}}$$

Factors in determining SRT:

1. Solids leaving the system (wasted)
2. Solids leaving the system (SS in the final effluent)
3. Solids in the system (aeration basins and clarifiers)

Example:

Tank volumes:      Aeration volume = 1.6 mg  
                              Final Clarifer volume = .10 mg

SS Concentration: Final effluent = 20 mg/l  
                              Waste sludge SS = 7,250 mg/l  
                              Aeration Tank MLSS = 2,500 mg/l

Flows:                    Influent flow = 4.3 mgd  
                              Waste sludge flow = 0.08 mgd (24-hour period)

Using these figures, calculate the amount of suspended solids leaving the system:

*Example:*

$$(7,250 \text{ mg/l waste sludge}) \times (.08 \text{ waste sludge flow}) \times (8.34 \text{ lbs.})$$
$$+ (20 \text{ mg/l SS final effluent}) \times (4.3 \text{ MGD influent flow}) \times (8.34 \text{ lbs.})$$
$$= 4,837.2 \text{ lbs. SS} + 717.2 \text{ lbs. SS} = 5,554.4 \text{ lbs. SS leaving system}$$

For this example, the volume of the aeration tank and clarifier equals 1.7 mg.

$$\text{Pounds of Aeration Tank MLSS} =$$
$$\text{Aeration Tank mg/l MLSS} \times \text{mg} \times 8.34$$

*Example:*

$$2,500 \text{ mg/l MLSS} \times 1.7 \text{ mg volume} \times 8.34 \text{ lbs.} = 35,445 \text{ lbs. MLSS}$$

$$\text{Solids Retention Time (SRT):}$$
$$\text{SRT days} = \frac{\text{lbs./day of SS in system}}{\text{lbs./day of SS leaving system}}$$

*Example:*

$$\frac{35,445 \text{ lbs. MLSS}}{5,554.4 \text{ lbs. SS leaving system}} = 6.38 \text{ SRT}$$

# Activated Sludge Calculations

## F/M Ratio

Ratio of food (biochemical oxygen demand) entering the aeration tank to microorganisms in the tank.

$$\text{F/M Ratio:} \\ \frac{\text{lbs./BOD}}{\text{lbs. MLSS}}$$

*Example:*

lbs. of BOD entering plant daily = 4,340 lbs.

lbs. of MLSS in aerator = 8,201 lbs.

$$\frac{\text{lbs. BOD}}{\text{lbs. MLSS}} \text{ or } \frac{4,340 \text{ lbs. of BOD entering plant daily}}{8,201 \text{ lbs. of MLSS in aerator}} = .53 \text{ F/M}$$

## MLSS Concentration in Pounds

Pounds of MLSS in the aeration system.

$$\text{MLSS Concentration:} \\ \text{MLSS (mg/l) x volume of aeration tank x 8.34}$$

*Example:*

MLSS in aeration tank = 2,500 mg/l

Aeration system volume = 1.4 mg

$$\text{MLSS (mg/l) x volume of aeration tank x 8.34} \\ 2,500 \text{ mg/l x } 1.4 \text{ x } 8.34 = 29,190 \text{ lbs. of MLSS}$$

## Solids to be Wasted

Solids (measured in pounds) to be wasted over a set period of time (typically daily).

$$\text{Solids to be Wasted:} \\ \text{Current inventory} \\ - \text{Desired inventory to achieve peak performance} \\ = \text{Pounds to be wasted}$$

After calculating the MLSS Concentration (see above), use the following formula to determine the pounds of solids to be wasted.

*Example:*

Peak performance = 22,000 pounds of MLSS in aeration system

Current inventory = 25,000 pounds of MLSS in aeration system

$$25,000 \text{ pounds (current inventory)} \\ - 22,000 \text{ pounds (desired inventory)} \\ = 3,000 \text{ pounds to be wasted}$$

# Activated Sludge Calculations

## Waste Sludge Pumping Rate

Rate at which to pump the sludge to be wasted from the system. Normally expressed in gallons per minute (gpm).

*Example:*

Plant Conditions:

lbs. of MLSS to be wasted = 1,400 lbs.

MLSS concentration = 5,900 mg/l

$$\frac{\text{lbs. to be wasted}}{\text{MLSS concentration} \times 8.34} = \text{flow rate (mgd)}$$

*Example:*

$$\frac{1,400 \text{ lbs. to be wasted}}{5,900 \text{ mg/l} \times 8.34} = .0284 \text{ mgd wasting rate}$$

Convert million gallons per day to gallons per day:

$$\text{mgd wasting rate} \times 1,000,000 = \text{gpd wasting rate}$$

*Example:*           .0284 x 1,000,000 = 28,400 gpd

Convert gallons per day to gallons per minute (over 8 hours):

$$\frac{\text{gpd wasting rate}}{480 \text{ minutes (8 hours)}}$$

*Example:*            $\frac{28,400 \text{ gpd}}{480 \text{ minutes}} = 59.166 \text{ gpm}$

## Typical WWTP Operational Parameters

Process	BOD Loading, lb BOD/day per 1,000 ft. 3	MLSS, mg/l	F:M ratio, lb BOD/day per lb MLSS	Sludge Age, days	Aeration period, hr	RAS Rates, %	BOD Removal Efficiency %
Conventional	20-40	1,000-3,000	0.2 - 0.5	5 - 15	4.0 - 7.5	20 - 40	80 - 90
Step Aeration	40-60	1,500 -3,500	0.2 -0.5	5 - 15	4.0 - 7.0	30 - 50	80 - 90
Extended Aeration	10 - 20	2,000 - 8,000	0.05 - 0.2	> 20	20 - 30	50 - 100	85 - 95
High - purity oxygen	> 120	4,000 - 8,000	0.6 - 1.5	3 - 10	1.0 - 3.0	30 - 50	80 - 90

# Metal Salt Addition for Phosphorus Removal

Using metal salt chemical data, theoretically calculate the amount of chemical salt solution to add in gallons per day to remove phosphorus.

\* Values that need to be entered are shown in the gray boxes.

**Step 1. Determine the amount of influent phosphorus to remove.**

Influent flow in MGD	X	Influent P (mg/l)	X	lbs/gallon	=	lbs of P to remove
2		8		8.34		133

**Step 2. Determine the pounds of metal salt in a gallon of solution knowing the specific gravity.**

Specific gravity	X	lbs/gal	=	lbs metal salt/gal
1.4		8.34		11.7

Chemical	Specific Gravity
Alum	1.33
Ferric Chloride	1.441
Ferrous Chloride	1.23
Ferrous Sulfate	1.185

**Step 3. Determine the pounds of actual metal in a gallon of metal salt solution with certain percentage metal content (provided by chemical supplier).**

lbs metal salt/gal	X	% metal	=	lbs metal/gal metal salt solution
11.7		12.5		1.5

**Step 4. Look up removal ratio for the metal salt being used.**

Chemical	Removal Ratio
Alum	0.87 to 1
Ferric Chloride	1.8 to 1
Ferrous Chloride	2.7 to 1
Ferrous Sulfate	2.7 to 1

**Step 5. Determine the pounds of metal needed to remove the incoming pounds of phosphorus.**

Removal ratio	X	Influent lbs of P	=	lbs of metal to add
1.8		133		240

**Step 6. Determine the gallons of metal salt solution with a certain percentage metal content to thus add.**

lbs of metal to add	÷	lbs of metal/gal	=	gal/day of metal salt solution to add
240		1.5		165

This estimate may be different than the value obtained from a calculator due to rounding differences.



This spreadsheet was developed by the Wisconsin Department of Natural Resources and the Operator Certification Phosphorus Removal Exam Workgroup (2008)

# Water/Wastewater Operations



Baxter & Woodman provides a full range of services to meet your daily and long-term operational needs, complemented by a staff that provides customized Municipal Engineering Services. Licensed and certified operators are available to assist with your water and wastewater operations needs.

## Wastewater

- Operational assistance
- Startup
- Troubleshooting
- O&M manual preparation
- Lab assistance
- DMR reports
- NPDES permit applications
- Land application permits
- Plant sampling programs
- Maintenance programs
- Operator training
- Odor control issues

## Water

- Operational assistance
- Startup
- Troubleshooting
- O&M Manual preparation
- Permit applications
- Water modeling
- Lab assistance
- Consumer Confidence Reports
- Sampling programs
- Maintenance programs
- Operator training
- Unidirectional flushing
- Cross connection programs

## Miscellaneous

- Construction services support
- Water/Sewer rate studies
- Value engineering
- Regulatory issues resolution
- SCADA systems
- Fiscal reports
- Engineering design
- GIS tracking system
- Grant and loan funding
- SPCC plans
- Safety compliance program
- Safety training programs
- Safety audits

## Licenses/Certifications

### USEPA

- Pretreatment Training
- Industrial User Classification & Permitting

### OSHA

- Authorized Trainer

## Pretreatment

- Develop pretreatment ordinances
- Develop sampling programs
- Develop technically-based Local Limits
- Enforcement response plans
- Permitting for SIU's

*Qualified staff is available to meet with you on site.  
Call 815-459-1260 for additional information  
or to schedule an appointment.*



[www.baxterwoodman.com](http://www.baxterwoodman.com)



Baxter & Woodman, Inc. is an employee-owned engineering consulting firm which provides planning, design, construction and technology services for water, wastewater, stormwater and transportation facilities for municipalities, counties and state agencies throughout the Midwest.

Founded in 1946, Baxter & Woodman is one of the largest regionally focused engineering firms in the Midwest. Clients are served from nine regional offices. Baxter & Woodman's staff of 200 engineers, surveyors, technicians and support personnel has completed projects for more than 500 municipalities and county governments.

*Water Wastewater Transportation GIS  
Stormwater Construction Municipal Services*

### Office Network

**Crystal Lake**  
8678 Ridgefield Rd.  
Crystal Lake, IL 60012  
815.459.1260

**Burlington**  
256 S. Pine St.  
Burlington, WI 53105  
262.763.7834

**Grayslake**  
31 S. Seymour Ave.  
Grayslake, IL 60030  
847.223.5088

**Madison**  
5100 Eastpark Blvd.  
Suite 200  
Madison, WI 53718  
608.241.5481

**Plainfield**  
24402 S. Lockport St.  
Suite 227  
Plainfield, IL 60544  
815.609.7425

**Chicago**  
39 S. LaSalle St.  
Suite 816  
Chicago, IL 60603  
312.578.0050

**DeKalb**  
1788 Sycamore Rd.  
DeKalb, IL 60115  
815.787.3111

**Itasca**  
300 Park Blvd.  
Suite 355  
Itasca, IL 60143  
630.773.1870

**Mokena**  
8840 W. 192nd St.  
Mokena, IL 60448  
708.478.2090

[www.baxterwoodman.com](http://www.baxterwoodman.com)  
[info@baxterwoodman.com](mailto:info@baxterwoodman.com)